

**CITY OF EASTLAKE - BUILDING DEPARTMENT
35150 LAKESHORE BLVD., EASTLAKE, OHIO 44095
(440) 951-1416 EXT. 117 FAX: (440) 975-4280**

WATERPROOFING PERMIT APPLICATION

JOB ADDRESS _____

PRINT OWNERS NAME _____

OWNERS PHONE NUMBER _____

GENERAL CONTRACTOR _____

COMPANY ADDRESS _____ PHONE NO. _____

CONTRACT VALUE _____

DESCRIPTION OF WORK _____

REQUIREMENTS

1. SECTION R405, FOUNDATION DRAINAGE

R405.1 Concrete or masonry foundations. Drains shall be provided around all concrete or masonry foundations that retain earth and enclose habitable or usable spaces located below grade. Drainage tiles, gravel or crushed stone drains, perforated pipe or other approved systems or materials shall be installed at or below the area to be protected and shall discharge by gravity or mechanical means into an approved drainage system. Gravel or crushed stone drains shall extend at least 1 foot (305 mm) beyond the outside edge of the footing and 6 inches (152 mm) above the top of the footing **and be covered with an approved filter membrane material.** The top of open joints of drain tiles shall be protected with strips of building paper, and the drainage tiles or perforated pipe shall be placed on a minimum of 2 inches (51 mm) of washed gravel or crushed rock at least one sieve size not less than 6 inches (152 mm) of the same material.

Exception: A drainage system is not required when the foundation is installed on well-drained ground or sand-gravel mixture soils according to the Unified Soil Classification System, Group I Soils, as detailed in Table R405.1. **PROVIDE RESULTS FROM TESTING AGENCY.**

2. SECTION R406, FOUNDATION WATERPROOFING AND DAMPPROOFING

R406.1 Concrete and masonry foundation damp proofing. Except where required by Section R406.2 to be waterproofed, foundation walls that retain earth and enclose interior spaces and floors below grade shall be damp proofed from the top of the footing to the finished grade. Masonry walls shall have not less than 3/8 inch (9.5 mm) portland cement parging applied to the exterior of the wall. The parging shall be damp proofed in accordance with one of the following:

1. Bituminous coating.
2. 3 pounds per square yard (1.63 kg/m²) of acrylic modified cement.
3. 1/8-inch (3.2 mm) coat of surface-bonding cement complying with ASTM C 887.
4. Any material permitted for waterproofing in Section R406.2.
5. Other approved methods or materials. Prior to approval is required from the Building Department as to materials used.

Exception: Parging of unit masonry walls is not required where a material is approved for direct application to the masonry. Concrete walls shall be damp proofed by applying any one of the above listed damp proofing materials or any one of the waterproofing materials listed in Section R406.2 to the exterior of the wall.

R406.2 Concrete and masonry foundation waterproofing. In areas where a high water table or other severe soil-water conditions are known to exist, exterior foundation walls that retain earth and enclose interior spaces and floors below grade shall be waterproofed from the top of the footing to the finished grade. Walls shall be waterproofed in accordance with one of the following:

- | | | |
|-----------------------------------|--------------------------------------|---|
| 1. 2-ply hot-mopped felts | 3. 6-mil (.15mm) polyvinyl chloride. | 5. 40-mil (1 mm) polymer-modified asphalt |
| 2. 55 pounds (25 kg) roll roofing | 4. 6-mil (0.15mm) polyethylene | 6. Design by professional |

(ACCORDING TO THE CITY ENGINEER, MOST AREAS IN THE CITY OF EASTLAKE HAS A HIGH WATER TABLE)

3. INSPECTIONS REQUIRED

First Inspection. A. Parging is 100% complete. B. The foundation wall is 100% sealed for damp proofing with a bituminous coating and for waterproofing in areas with areas with a high water table the membrane covering shall in stalled, lapped a minimum of 6 inches and sealed. C. Minimum of 2 inches of gravel base installed below the drainage tile or perforated piping. D. Drainage piping is 100%, if the piping has the approved filter membrane completely around the drainage piping, this will be inspected at this time. Contact the Building Department at (440-951-1416 ext. 117) for inspection of the foundation wall and piping requirements; Contact the Service Department at 440-951-1416 ext. 140 for drainage connection inspections at this time.

Second Inspection. If the filter membrane is not used around drainage piping, a minimum of 6 inches of gravel shall be installed above the drainage piping and the approved filter membrane shall be completely in place on top of the gravel. If the filter membrane was installed around the piping and passed the first inspection, call for the second inspection when gravel is backfilled and top soil is on site but not backfilled.

Final Inspection. When completely backfilled with top-soil and the entire area is properly graded, seeded with lawn seeds and/or original flower bed or shrubs are re-planted and all downspouts are connected.

IF ANY OF THE ABOVE IS NOT COMPLETE AT TIME OF INSPECTION A RE-INSPECTION FEE WILL APPLY.

The excess dirt after backfilling around the foundation shall be removed from the site and not be used to re-grade the yard.

See Service Department for backfilling requirements from drain connection to street connection.

THE ABOVE IS A TRUE DESCRIPTION OF THE LOT AND I AGREE TO ALL OF THE REQUIREMENTS. THE ACCEPTANCE OF THE PERMIT HEREIN APPLIED FOR SHALL CONSTITUTE AN AGREEMENT ON MY PART TO ABIDE BY ALL CONDITIONS HEREIN CONTAINED AND ALSO TO COMPLY WITH ALL ORDINANCES SET FORTH BY THE CITY OF EASTLAKE, AND THE LAWS OF THE STATE OF OHIO RELATING TO THE WORK TO BE DONE THEREUNDER AND SAID AGREEMENT IS A CONDITION OF SAID PERMIT.

IMPORTANT NOTICE TO HOMEOWNERS: IF YOU OBTAIN THIS PERMIT ON THE BEHALF OF A CONTRACTOR YOU ARE LIABLE FOR ALL WWORK INCLUDING ANY VIOLATIONS OF UNFINISHED WORK. ALL CONTRACTORS MUST BE CURRENTLY REGISTERED WITH THE CITY.

SIGNATURE OF:

OWNER/CONTRACTOR _____

PRINT NAME _____

